

According to Commission Regulation (EU) No 206/2012

| Function (indicate if percent)  |          |       |      | If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average' |        |       |      |
|---|----------|-------|------|---|--------|-------|------|
| cooling   |          | Y     |      | Average   |        |       | Y    |
| heating   |          | Y     |      | Warmer<br>(if designated)   |        |       | Y    |
|   |          |       |      | Colder<br>(if designated)   |        |       | N    |
| Item  | symbol   | value | unit | Item  | symbol | value | unit |
| Design load   |          |       |      | Seasonal efficiency   |        |       |      |
| Cooling   | Pdesignc | 6,5   | kW   | cooling   | SEER   | 7,0   | -    |
| heating/Average   | Pdesignh | 4,1   | kW   | heating/Average   | SCOP/A | 4,3   | -    |
| heating/Warmer  | Pdesignh | 2,2   | kW   | heating/Warmer  | SCOP/W | 5,3   | -    |
| heating/Colder  | Pdesignh | -     | kW   | heating/Colder  | SCOP/C | -     | -    |
| Declared capacity(*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj            |          |       |      | Declared energy efficiency ratio(*), at indoor temperature 27(19) °C and outdoor temperature Tj   |        |       |      |
| Item  | symbol   | value | unit | Item  | symbol | value | unit |
| Tj = 35 °C  | Pdc      | 6,5   | kW   | Tj = 35 °C  | EERd   | 3,33  | -    |
| Tj = 30 °C  | Pdc      | 4,6   | kW   | Tj = 30 °C  | EERd   | 5,2   | -    |
| Tj = 25 °C  | Pdc      | 2,9   | kW   | Tj = 25 °C  | EERd   | 7,8   | -    |
| Tj = 20 °C  | Pdc      | 1,8   | kW   | Tj = 20 °C  | EERd   | 13,4  | -    |
| Declared capacity(*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj |          |       |      | Declared coefficient of performance(*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj   |        |       |      |
| Tj = -7 °C  | Pdh      | 3,7   | kW   | Tj = -7 °C  | COPd   | 3,1   | -    |
| Tj = 2 °C   | Pdh      | 2,2   | kW   | Tj = 2 °C   | COPd   | 4,2   | -    |
| Tj = 7 °C   | Pdh      | 1,5   | kW   | Tj = 7 °C   | COPd   | 5,3   | -    |
| Tj = 12 °C  | Pdh      | 1,5   | kW   | Tj = 12 °C  | COPd   | 6,6   | -    |
| Tj = bivalent temperature   | Pdh      | 4,1   | kW   | Tj = bivalent temperature   | COPd   | 2,7   | -    |
| Tj = operating limit  | Pdh      | 4,1   | kW   | Tj = operating limit  | COPd   | 2,7   | -    |
| Declared capacity(*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj  |          |       |      | Declared coefficient of performance(*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj  |        |       |      |
| Tj = 2 °C   | Pdh      | 2,2   | kW   | Tj = 2 °C   | COPd   | 4,2   | -    |
| Tj = 7 °C   | Pdh      | 1,5   | kW   | Tj = 7 °C   | COPd   | 5,3   | -    |
| Tj = 12 °C  | Pdh      | 1,5   | kW   | Tj = 12 °C  | COPd   | 6,6   | -    |
| Tj = bivalent temperature   | Pdh      | 2,2   | kW   | Tj = bivalent temperature   | COPd   | 4,2   | -    |
| Tj = operating limit  | Pdh      | 4,1   | kW   | Tj = operating limit  | COPd   | 2,7   | -    |
| Declared capacity(*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj  |          |       |      | Declared coefficient of performance(*)/Colder season, at indoor temperature 20 °C and outdoor temperature Tj  |        |       |      |
| Tj = -7 °C  | Pdh      | -     | kW   | Tj = -7 °C  | COPd   | -     | -    |
| Tj = 2 °C   | Pdh      | -     | kW   | Tj = 2 °C   | COPd   | -     | -    |
| Tj = 7 °C   | Pdh      | -     | kW   | Tj = 7 °C   | COPd   | -     | -    |
| Tj = 12 °C  | Pdh      | -     | kW   | Tj = 12 °C  | COPd   | -     | -    |
| Tj = bivalent temperature   | Pdh      | -     | kW   | Tj = bivalent temperature   | COPd   | -     | -    |
| Tj = operating limit  | Pdh      | -     | kW   | Tj = operating limit  | COPd   | -     | -    |
| Tj = -15 °C   | Pdh      | -     | kW   | Tj = -15 °C   | COPd   | -     | -    |
| Bivalent temperature  |          |       |      | Operating limit temperature   |        |       |      |
| heating/Average   | Tbiv     | -10   | °C   | heating/Average   | Tol    | -11   | °C   |
| heating/Warmer  | Tbiv     | 2     | °C   | heating/Warmer  | Tol    | -11   | °C   |
| heating/Colder  | Tbiv     | -     | °C   | heating/Colder  | Tol    | -     | °C   |
| Cycling interval capacity   |          |       |      | Cycling interval efficiency   |        |       |      |
| for cooling   | Pcycc    | -     | kW   | for cooling   | EERcyc | -     | -    |
| for heating   | Pcyh     | -     | kW   | for heating   | COPcyc | -     | -    |
| Degradation co-efficient cooling(**)  | Cdc      | 0,25  | kW   | Degradation co-efficient heating(**)  | Cdh    | 0,25  | -    |

| Electric power input in power modes other than 'active mode' |                  |        |    | Annual electricity consumption     |                 |             |                       |
|--|------------------|--------|----|------------------------------------|-----------------|-------------|-----------------------|
| off mode   | P <sub>OFF</sub> | 0,0015 | kW | cooling                            | Q <sub>CE</sub> | 325         | kWh/a                 |
| standby mode   | P <sub>SB</sub>  | 0,0015 | kW | heating/Average                    | Q <sub>HE</sub> | 1335        | kWh/a                 |
| thermostat-off mode  | P <sub>TO</sub>  | 0,008  | kW | heating/Warmer                     | Q <sub>HE</sub> | 581         | kWh/a                 |
| crankcase heater mode  | P <sub>CK</sub>  | 0      | kW | heating/Colder                     | Q <sub>HE</sub> | -           | kWh/a                 |
| Capacity control (indicate one of three options)             |                  |        |    | Other items                        |                 |             |                       |
| fixed  | N                |        |    | Sound power level (indoor/outdoor) | L <sub>WA</sub> | 62,0 / 68,0 | dB(A)                 |
| staged   | N                |        |    | Global warming potential           | GWP             | 675         | kgCO <sub>2</sub> eq. |
| variable   | Y                |        |    | Rated air flow (indoor/outdoor)    | -               | 1100/3000   | m <sup>3</sup> /h     |
| Contact details for obtaining more information               |                  |        |    |                                    |                 |             |                       |

(\*) For staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of unit.

(\*\*) If default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.

# SAMSUNG

eyoung.bae