

According to Commission Regulation (EU) No 206/2012

Function (indicate if present)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'			
cooling		Y		Average		Y	
heating		Y		Warmer (if designated)		Y	
				Colder (if designated)		N	
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
Cooling	P _{designc}	4,3	kW	cooling	SEER	8,2	-
heating/Average	P _{designh}	2,7	kW	heating/Average	SCOP/A	4,6	-
heating/Warmer	P _{designh}	1,5	kW	heating/Warmer	SCOP/W	5,6	-
heating/Colder	P _{designh}	-	kW	heating/Colder	SCOP/C	-	-
Declared capacity(*) for cooling, at indoor temperature 27(19) °C and outdoor temperature T _j				Declared energy efficiency ratio(*), at indoor temperature 27(19) °C and outdoor temperature T _j			
Item	symbol	value	unit	Item	symbol	value	unit
T _j = 35 °C	P _{dc}	4,3	kW	T _j = 35 °C	EERd	3,6	-
T _j = 30 °C	P _{dc}	3,0	kW	T _j = 30 °C	EERd	5,6	-
T _j = 25 °C	P _{dc}	1,9	kW	T _j = 25 °C	EERd	9,9	-
T _j = 20 °C	P _{dc}	1,1	kW	T _j = 20 °C	EERd	17,4	-
Declared capacity(*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature T _j				Declared coefficient of performance(*)/Average season, at indoor temperature 20 °C and outdoor temperature T _j			
T _j = -7 °C	P _{dh}	2,4	kW	T _j = -7 °C	COPd	3,1	-
T _j = 2 °C	P _{dh}	1,5	kW	T _j = 2 °C	COPd	4,6	-
T _j = 7 °C	P _{dh}	1,0	kW	T _j = 7 °C	COPd	5,7	-
T _j = 12 °C	P _{dh}	0,9	kW	T _j = 12 °C	COPd	6,8	-
T _j = bivalent temperature	P _{dh}	2,7	kW	T _j = bivalent temperature	COPd	2,8	-
T _j = operating limit	P _{dh}	2,7	kW	T _j = operating limit	COPd	2,7	-
Declared capacity(*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature T _j				Declared coefficient of performance(*)/Warmer season, at indoor temperature 20 °C and outdoor temperature T _j			
T _j = 2 °C	P _{dh}	1,5	kW	T _j = 2 °C	COPd	4,6	-
T _j = 7 °C	P _{dh}	1,0	kW	T _j = 7 °C	COPd	5,7	-
T _j = 12 °C	P _{dh}	0,9	kW	T _j = 12 °C	COPd	6,8	-
T _j = bivalent temperature	P _{dh}	1,5	kW	T _j = bivalent temperature	COPd	4,6	-
T _j = operating limit	P _{dh}	2,7	kW	T _j = operating limit	COPd	2,7	-
Declared capacity(*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature T _j				Declared coefficient of performance(*)/Colder season, at indoor temperature 20 °C and outdoor temperature T _j			
T _j = -7 °C	P _{dh}	-	kW	T _j = -7 °C	COPd	-	-
T _j = 2 °C	P _{dh}	-	kW	T _j = 2 °C	COPd	-	-
T _j = 7 °C	P _{dh}	-	kW	T _j = 7 °C	COPd	-	-
T _j = 12 °C	P _{dh}	-	kW	T _j = 12 °C	COPd	-	-
T _j = bivalent temperature	P _{dh}	-	kW	T _j = bivalent temperature	COPd	-	-
T _j = operating limit	P _{dh}	-	kW	T _j = operating limit	COPd	-	-
T _j = -15 °C	P _{dh}	-	kW	T _j = -15 °C	COPd	-	-
Bivalent temperature				Operating limit temperature			
heating/Average	T _{biv}	-10	°C	heating/Average	T _{ol}	-11	°C
heating/Warmer	T _{biv}	2	°C	heating/Warmer	T _{ol}	-11	°C
heating/Colder	T _{biv}	-	°C	heating/Colder	T _{ol}	-	°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	P _{cycc}	-	kW	for cooling	EER _{cycc}	-	-
for heating	P _{cyhc}	-	kW	for heating	COP _{cyhc}	-	-
Degradation co-efficient cooling(**)	C _{dc}	0,25	kW	Degradation co-efficient heating(**)	C _{dh}	0,25	-
Electric power input in power modes other than 'active mode'				Annual electricity consumption			
off mode	P _{off}	0,0015	kW	cooling	Q _{CE}	184	kWh/a
standby mode	P _{sb}	0,0015	kW	heating/Average	Q _{HE}	822	kWh/a
thermostat-off mode	P _{to}	0,01	kW	heating/Warmer	Q _{HE}	375	kWh/a
crankcase heater mode	P _{ck}	0	kW	heating/Colder	Q _{HE}	-	kWh/a
Capacity control (indicate one of three options)				Other items			
fixed	N			Sound power level (indoor/outdoor)	L _{WA}	58,0 / 65,0	dB(A)
staged	N			Global warming potential	GWP	675	kgCO ₂ eq.
variable	Y			Rated air flow (indoor/outdoor)	-	800/2700	m ³ /h
Contact details for obtaining more information							

(*) For staged capacity units, two values divided by a slash (/) will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of unit.

(**) If default C_d = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.